

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1597:111 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: TEPG – US, 91 Technology Drive, Westminster, MA 01441-*0001
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models 430654, *T360-9052, *T360-9053, T360-9935, and T360-9836 photoelectric type air duct smoke detector units. Unit consists of a listed detector head, base, a sampling and an exhaust tube and an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Air Velocity: 300 - 4000 feet/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical & air velocity rating, and UL label.

APPROVAL: Listed as duct smoke detector unit for installation in HVAC systems when used with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details

XLf: 3240-0026:241

*Rev. 11-06-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 6, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**